

## **RFQ Substation Equipment Q&A**

Q: The attached SLD E701 shows all fixed mounted equipment for the 27KV line-ups but, the spec is written for a metal clad switchgear assembly. Are we to quote the 27KV assembly per the SLD with all fixed mounted equipment?

**A: Metal Clad switch gear assembly**

Q: Both the 5KV & 27KV specs require a CPT but, are absent from the SLD. We are proposing to quote a single 50-75KVA CPT sized for both walk-ins aisles

**A: Yes.**

Q: We are also proposing a dedicated battery system in each walk-in aisle

**A: Yes.**

Q: Is the above acceptable?

**A: Yes.**

Q: This project that is bidding on April 1<sup>st</sup>, is this project equipment supply only? No electrical install?

**A: Yes. That is correct.**